



Environmental Hazards Services, LLC

7469 Whitepine Rd. • Richmond, VA 23237 • 800-347-4010 • jdickerson@leadlab.com

October 24, 2017

LEW Corp
181 US Highway 46
Mine Hill, NJ 07803

PROJECT INFORMATION

Project/Test Address: 170837; Roosevelt School #7; 225 Lincoln Place; Garfield, NJ

Report Number: 17-10-02746

Analysis Type: Lead – Standard Method 3113B

Lab Accreditation

Number: NJ-VA008/NY-11714

Results, Discussion

Qualifiers: N/A

A handwritten signature in cursive script that reads 'Julie Dickerson'.

Julie Dickerson
Laboratory Administrator
Environmental Hazards Services, LLC



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Report Number: 17-10-02746

Client: LEW Corp
 181 US Hwy 46
 Mine Hill, NJ 07803

Received Date: 10/18/2017
 Reported Date: 10/24/2017
 Sampled By: Rita Vilorio
 Tech Certification #:

Project/Test Address: 170837; Roosevelt School #7; 225 Lincoln Place; Garfield, NJ

Client Number:
 201327

Laboratory Results

Fax Number:
 Ext 18

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
17-10-02746-001	1-RS-DW	10/16/2017	BY ROOM 2-07	193	10/20/2017	
17-10-02746-002	2-RS-C	10/16/2017	FACULTY ROOM	<1.00	10/20/2017	
17-10-02746-003	3-RS-DW	10/16/2017	BY ROOM 2-01	11.8	10/20/2017	
17-10-02746-004	4-RS-DW	10/16/2017	ACROSS RM HO	17.4	10/20/2017	
17-10-02746-005	5-RS-C	10/16/2017	NURSE OFFICE	<1.00	10/20/2017	
17-10-02746-006	6-RS-DW	10/16/2017	BY ROOM 1-01	15.0	10/20/2017	
17-10-02746-007	8-RS-DW	10/16/2017	ACROSS CAFETERIA	17.3	10/20/2017	
17-10-02746-008	9-RS-S	10/16/2017	CAFETERIA	7.55	10/20/2017	
17-10-02746-009	10-RS-S	10/16/2017	CAFETERIA	5.28	10/20/2017	
17-10-02746-010	11-RS-S	10/16/2017	CAFETERIA	3.55	10/20/2017	
17-10-02746-011	12-RS-DW	10/16/2017	BASEMENT NEAR BOYS BATHROOM	25.8	10/20/2017	
17-10-02746-012	101-RS-S	10/16/2017	STADIUM	<1.00	10/20/2017	

Environmental Hazards Services, L.L.C

Client Number: 201327

Report Number: 17-10-02746

Project/Test Address: 170837; Roosevelt School #7; 225 Lincoln Place;
Garfield, NJ

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
-------------------	------------------	-----------------	---------------------	--------------------------	---------------	--------------

Method: SM 3113B-2010
Analyst: Jennalee Zlotkowski
Accreditation #: NJ VA008

Reviewed By Authorized Signatory: *Melissa Kanode*

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



Eho Laboratories
 ENVIRONMENTAL HAZARD SERVICES, LLC

Water Chain-of-Custody Form

SHIP TO: 7469 Whitepine Rd., Richmond, VA 23237
 Phone: (800) 347-4010 FAX: (804) 275-4907
 ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

17-10-02746



Due Date:
10/25/2017
 (Wednesday)
 AE

Company Name: LEW Corporation

Address: 10996 Bristol Road

Phone: 908-654-8068

Email: labresults@lewcorp.com

Fax: 908-654-8069

Account #: 201327

City/State/Zip: Mountainside, NJ 07092

Project Name / Collection Address: **17037 ROOSEVELT SCHOOL #3**

2 AS LINCOLN PLACE

City/State/Zip: **GARFIELD NJ**

P.O. #: **RITA VALERIO**

Sampled By: **RITA VALERIO**

License # (if Required):

Water Sources (Check One) Public Well

Well Tag # (if Applicable):

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters Field pH at time of Collection	LAB USE Temp at Time of Receipt
					Lead	Copper	Other		
1	1-DW - DW	BY ROOM 2-07	10/14/17	7	AM/PM				
2	2-C - C	FACULTY ROOM			AM/PM				
3	3-DW - DW	BY ROOM 2-01			AM/PM				
4	4-C - C	ACROSS RM 40			AM/PM				
5	5-DW - DW	NURSE OFFICE			AM/PM				
6	6-C - C	BY ROOM 1-01			AM/PM				
7	7-DW - DW	ROOM 1-05			AM/PM				
8	8-DW - DW	ACROSS CAFETERIA			AM/PM				
9	9-S - S	CAFETERIA			AM/PM				
10	10-V - V	S			AM/PM				

Released by: **Rita V**

Signature: *Rita V*

Date/Time: **10/16/17**

Released by:

Signature:

Date/Time:

10/18/17



ENVIRONMENTAL HAZARDS SERVICES, LLC

Water Chain-of-Custody Form

SHIP TO: 7469 Whitepine Rd. Richmond, VA 23237

Phone: (800) 347-4010 FAX: (804) 275-4907

ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

Company Name: LEW Corporation

Address: 1090 Bristol Road

Phone: 908-654-8068

Email: labresults@lewcop.com

Account #: 201327

City/State/Zip: Mountainside, NJ 07092

Fax: 908-654-8069

Project Name / Collection Address: **GAPA# 1 1225 UNCON**

City/State/Zip: **C GARFIELD NJ**

License # (if Required):

P.O. #: **RITA VILLORID** Sampled By: **RITA VILLORID**

Water Source: (Check One) Public Well

Well Tag # (if Applicable):

No.	Client Sample ID	Collection Location (Exc Kitchen Sink)	Collection Date	Collection Time	Metals			Field Parameters	LAB USE
					Lead	Copper	Other		
1	11-PS-S	CAFETERIA	10/14/17	AM/PM	X				
2	10-RS-DN	BASMENT NEAR BOYS BATHROOM		AM/PM					
3	101-RS-S	STADIUM		AM/PM					
4									
5	1-GPPAI-DN	MAIN ENTRANCE	10/14/17	AM/PM					
6	2--DN			AM/PM					
7	3--C	MAIN OFFICE		AM/PM					
8	4--C			AM/PM					
9	5--S			AM/PM					
10	101-GPPAI-S	STADIUM		AM/PM					

Released by: **RITA V** Signature: *[Signature]*

Released by: **RITA V** Signature: *[Signature]*

Date/Time: 10/16/17

10/18/17

[Handwritten Signature]
~ For Lab Use Only ~
2746